

**U.S. Department of Labor**  
Occupational Safety and Health Administration

**Inspection Number:** 1371506  
**Inspection Date(s):** 01/11/2019 - 04/09/2019  
**Issuance Date:** 04/18/2019



**Citation and Notification of Penalty**

**Company Name:** Total Earth Services, LLC  
**Inspection Site:** 1601 SW Archer, Gainesville, FL 32608

**Citation 1 Item 1** Type of Violation: **Serious**

29 CFR 1926.652(a)(1): Each employee in an excavation was not protected from cave-ins by an adequate protective system designed in accordance with paragraph (b) or (c) of this section:

- a. On or about January 10, 2019, in a 16 foot deep excavation, an employee was not protected from cave-in, by the use of a protective system, exposing an employee to engulfment hazards.

**Date By Which Violation Must be Abated:**  
**Proposed Penalty:**

**Corrected During Inspection**  
**\$9282.00**

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.